

# Attestation

## EMICODE

On 6 October 2022, Eurofins Product Testing A/S received a sample of a joint Sealant with the product name:

**Sikaflex®-708 Construction, Sikaflex®  
Construction Purform®, Sikaflex® PRO Purform®,  
Sikaflex®-1A Plus Purform®, SikaHyflex®-160  
Construction FR, Sika® SB-1113**  
supplied by  
**Sika Services AG**

The emission of organic compounds from the sample were measured in accordance with the test method as defined by GEV in its version by March 2022 (see report No. 392-2022-00437201\_A\_EN).

**Evaluation of the test result according to EC 1 PLUS for Installation Products, Adhesives and Building Materials:**

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
  - The TVOC after 3 days was below the limit of 750 µg/m<sup>3</sup>.
  - The TVOC after 28 days was below the limit of 60 µg/m<sup>3</sup>.
  - The TSVOC after 28 days was below the limit of 40 µg/m<sup>3</sup>.
  - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
  - The sum of VOC without LCI-value after 28 days was below the limit of 40 µg/m<sup>3</sup>.
  - After 3 days the concentration of both formaldehyde and acetaldehyde were below the limit of 50 µg/m<sup>3</sup>.
  - The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
- 

This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

16 November 2022



Laura Hartung Sørensen  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager